



工程设计资质证书编号  
建筑甲级:A113007169  
园林甲级:A113007169  
规划乙级:城规142010  
市政乙级:A213007166  
人防乙级:A213007166

中盛弘宇建设科技有限公司  
Zhongsheng Hongyu Construction Technology Co., Ltd.

备注 NOTE

\*本图经施工图审查机构及消防审批部门审查合格方可用于施工。  
版权所有中盛弘宇建设科技有限公司所有，未经书面许可，不得翻  
印使用，更改和复制等其它用途。  
This drawing can only be used for construction after being  
examined to be qualified and approved by Drawing Appraisal  
Unit & Fire Control Committee. The copyright belongs to the  
Zhongsheng Hongyu Construction Technology Co., Ltd. Without  
written permission, it's prohibited to use, change or copy  
the drawing for other purposes.

合作设计单位 CO-OPERATED WITH

说明 EXPLAIN

审 定 APPROVED BY	支永涛	支永涛
审 核 VERIFIED BY	李 亮	
项目负责人 PROJECT CHIEF	宋志荣	宋志荣
专业负责人 PROFESSION CHIEF	支永涛	支永涛
校 对 CHECKED BY	周兴	周兴
设 计 DESIGNED BY	周浪	周浪



建设单位 CONSTRUCTION  
重庆华牧现代农业有限公司

工程名称 PROJECT  
华牧现代农业生态循环智能化康鸡项目配电工程

项目名称 SUB PROJECT

图纸名称 DRAWING TITLE  
10kV杆型组装图（供电电源接电杆）

工程编号 DRAW NO.			
阶段 PHASE	施工图	专业 SPECIALTY	电 气
比例 SCALE		图号 DRAW NO.	
日期 DATE	2023.04	版本号 VERSION NUMBER	A



说明:

- 1、材质：不锈钢；
- 2、规格：120mm（长）×80mm（宽）×9mm（厚）；
- 3、安装：采用6孔50mm长平头螺丝安装；
- 4、工艺：字体及图形采用雕刻方式。
- 5、电缆走向标识根据实际走向制作，每10米设置1块。