



工程设计资质证书编号
建筑甲级:A113007189
园林甲级:A113007189
规划乙级:城规12010
市政乙级:A213007186
人防乙级:A213007186

说明 EXPLAIN

备注 NOTE
•本图由施工图审查机构及质监部门审査合格后可用于施工。
•本图由设计单位设计并由设计单位所有。未经书面许可，不得擅自
使用、复制和修改等其他用途。
This drawing can only be used for construction after being
examined to be qualified and approved by Drawing Appraisal
Unit & Fire Control Committee. The copyright belongs to the
designing unit. It's prohibited to use, change or copy
the drawing for other purposes.

合作设计单位 CO-OPERATED WITH

10kV古*线

JKGJ-10kV-70.10

64号杆
终端杆

新装高压隔离开关1组
新装10kV避雷器1组

ZB-YJV22-8.7/15kV-3*95

TMY-3×(50×5) TMY-3×(50×5)

至1ZB低压总路进线柜

1ZB
SCB12-1600kVA
10(10.5)±2×5%/0.4kV
D/yn, 11
Uk=6.0%

“1ZB” 1600kVA箱变

TMY-3×(50×5)

至2ZB低压总路进线柜

2ZB
S13-M-400kVA
10(10.5)±5%/0.4kV
D/yn, 11
Uk=4.5%

“2ZB” 400kVA箱变

ZB-YJV22-8.7/15kV-3*50

审定 APPROVED BY	支永涛	支永涛
审核 VERIFIED BY	李亮	
项目负责人 PROJECT CHIEF	宋志荣	宋志荣
专业负责人 DIVISION CHIEF	支永涛	支永涛
校对 CHECKED BY	周兴	周兴
设计 DESIGNED BY	周浪	周浪

建设单位 CONSTRUCTION
重庆华牧现代农业有限公司

工程名称 PROJECT
华牧现代农业生态循环智能蛋鸡项目电气工程

项目名称 SUB PROJECT

图纸名称 DRAWING TITLE
电气主接线平面示意图

工程编号 JOB NO.	阶段 STAGE	施工图 DRAWING	专业 DISCIPLINE	电 气
比例 SCALE			图号 DRAWING NO.	
日期 DATE		2023.04	版本号 VERSION NUMBER	A