


工程设计资质证书编号:
建筑甲级:A113007189
园林甲级:A113007189
规划乙级:城规12010
市政乙级:A213007186
人防乙级:A213007186

备注 NOTE
*本图由施工图审查机构及消防审验部门审査合格后可用于施工。
版权归中盛弘宇建设科技有限公司所有。未经书面许可,不得擅自
使用、复制和修改等其他用途。
This drawing can only be used for construction after being
examined by the Drawing Appraisal Unit & Fire Control Committee. The copyright belongs to the
company. It's prohibited to use, change or copy
the drawing without written permission. It's prohibited to use, change or copy
the drawing for other purposes.

合作设计单位 CO-OPERATED WITH

说明 EXPLAIN



电力电缆管与其它管道、建筑物之间的最小净距

项目	平行(m)	交叉(m)
热管道及热力设备	2.0	0.5
可燃气体及易燃液体管道	1.0	0.5
油管道	1.0	0.5
其它管道	0.5	0.5
排水沟	1.0	0.5
公路	1.5	1.0
城市街道路面	1.0	0.7
建筑物基础	0.6	

审定 APPROVED BY	支永涛	支永涛
审核 VERIFIED BY	李亮	李亮
项目负责人 PROJECT CHIEF	宋志荣	宋志荣
专业负责人 DIVISION CHIEF	支永涛	支永涛
校对 CHECKED BY	周兴	周兴
设计 DESIGNED BY	周浪	周浪

建设单位 CONSTRUCTION
重庆华牧现代农业有限公司工程名称 PROJECT
华牧现代农业生态循环智能化项目电气工程

项目名称 SUB PROJECT

图纸名称 DRAWING TITLE
电缆通道施工图(直埋碳素波纹管)

工程编号 JOB NO.	阶段 STAGE	施工图 DRAWING	专业 DISCIPLINE	电 气
比例 SCALE			图号 DRAWING NO.	
日期 DATE			版本号 VERSION NUMBER	A

说明:

- 1、碳素波纹管需从电杆直埋至电缆井处。
- 2、直埋电缆通道需设置警示带。
- 3、碳素波纹管与电缆井连接时应衔接紧密，井口与管壁齐平。
- 4、直埋段共2米，施工完毕后需恢复沥青路面。